

# 3" to 10" Backflow Preventer in an Above Ground Box

INSTALLATION DRAWING #011, OCTOBER 11, 2007 M.T.B.

All Enclosures Must be ASSE 1060 Class II Certified or Greater. All Side Openings Are to Open in Such a Way That the Ends of the Test Cocks Are Openly Exposed for Testing Purposes. All Electrical Outlets Are to be GFCI With Exterior In-Use Covers Located Near One End of the Assembly and Above the Level of the Bottom of the Relief Valve.

