



"A"	"B"
6" – 10" D.I.	48" MIN. COVER
12" – 36" D.I.	54" MIN. COVER

CITY OF HIGH POINT
 NORTH CAROLINA
 ENGINEERING SERVICES DEPARTMENT
 APPROVED: FEBRUARY 4, 2007
 BSK
 DIRECTOR

ISSUED 02-01-07
 REVISIONS

STANDARD DRAWING FOR
 WATER PIPE COVER REQUIREMENTS
 FOR 6" – 36" D.I. WATER PIPE – PRESSURE CLASS 350

COVER.DWG

230.00

SHEET 1 OF 1