



- NOTES:**
- A. ALL PIPE ENTRANCES SHALL BE FACTORY FORMED AND A FLEXIBLE WATERTIGHT CONNECTOR SHALL BE USED. FOR AN EXISTING PRECAST MANHOLE OR A NEW LINE ENTRANCE, ALL HOLES MUST BE CORED AND A WATERTIGHT PIPE CONNECTOR INSTALLED.
 - B. IF THE CONTRACTOR CUTS OR BREAKS INTO THE MANHOLE AND THE MANHOLE IS DAMAGED, THE CONTRACTOR SHALL REPLACE THE MANHOLE AT NO COST TO THE CITY.
 - C. FLEXIBLE WATERTIGHT CONNECTOR SLEEVES SHALL MEET THE REQUIREMENTS OF ASTM C-923 AND SHALL BE MANUFACTURED BY PRESS SEAL GASKET CORP. (PSX AND CAST A SEAL 603/802), NPC INC. (KOR-N-SEAL), OR APPROVED EQUAL.
 - D. FLEXIBLE WATERTIGHT CONNECTOR SHALL BE CORRECTLY SIZED TO ACCOMMODATE THE PIPE O.D.

CITY OF HIGH POINT
 NORTH CAROLINA
 ENGINEERING SERVICES DEPARTMENT

APPROVED: MAY 3, 2007
 BSK
 DIRECTOR

| | |
|---------------|--|
| ISSUED 5-3-07 | |
| REVISIONS | |
| | |
| | |
| | |

STANDARD DRAWING FOR
FLEXIBLE WATERTIGHT CONNECTOR
 FOR FOR SANITARY SEWER MANHOLES

MH_BOOT.DWG
306.00
 SHEET 1 OF 1