



- NOTES:**
- A. ALL STANDARD SEWER MANHOLE SECTIONS SHALL MEET THE REQUIREMENTS OF CITY STD. NO. 301.
 - B. A DROP MANHOLE SHALL BE USED WHEN THE DIFFERENCE IN INVERT ELEVATIONS EXCEEDS (2.5) FEET.
 - C. AN INSIDE DROP SHALL BE USED ONLY WITH SPECIAL APPROVAL FROM THE PUBLIC SERVICES DEPARTMENT.
 - D. ALL INSIDE DROP PIPE AND FITTINGS SHALL BE EPOXY COATED DUCTILE IRON.
 - E. MAXIMUM OF ONE INSIDE DROP ALLOWED FOR 5' MANHOLE.

CITY OF HIGH POINT
 NORTH CAROLINA
 ENGINEERING SERVICES DEPARTMENT

ISSUED 5-3-07
 REVISIONS

STANDARD DRAWING FOR
INSIDE DROP MANHOLE

APPROVED MAY 3, 2007
 BSK
 DIRECTOR

WITH 5' DIAMETER SANITARY MANHOLE