



- NOTES:
- A. MANHOLE TO BE BUILT IN ACCORDANCE WITH CITY STD. NO. 300, OR NO. 301.
 - B. A DROP MANHOLE SHALL BE USED WHEN THE DIFFERENCE IN INVERT ELEVATIONS EXCEEDS (2.5) FEET.
 - C. ALL OUTSIDE DROP PIPE AND FITTINGS SHALL BE EPOXY COATED DUCTILE IRON.
 - D. THE VERTICAL DUCTILE IRON PIPE STACK SHALL BE RESTRAINED BY THE USE OF MEGALUGS OR OTHER APPROVED METHODS.

CITY OF HIGH POINT
 NORTH CAROLINA
 ENGINEERING SERVICES DEPARTMENT

APPROVED: MAY 3, 2007
 BSK
 DIRECTOR

ISSUED 5-3-07	REVISIONS

STANDARD DRAWING FOR
OUTSIDE DROP MANHOLE
 FOR SANITARY SEWER

MH_OUT_DR.DWG
314.00
 SHEET 1 OF 1