



GROUT PIPE INTO MH WITH
NON-SHRINK GROUT.
FLEXIBLE CONNECTOR IS
NOT ALLOWED.

EPOXY COATED RIGID
RESTRAINED JOINT D.I.P.

- NOTES:
- A. THE MANHOLE SHALL BE BUILT IN ACCORDANCE WITH THE APPLICABLE MANHOLE CITY STANDARD DRAWINGS.
 - B. THE ELEVATED SANITARY SEWER PIPE SHALL BE EPOXY-COATED, RIGID-RESTRAINED JOINT D.I.P., SUCH AS GRIFITN PIPE PRODUCTS CO. MECH-LOK OR OTHER APPROVED PIPE.
 - C. FILL BETWEEN THE BOTTOM SLAB AND ELEVATED FLOOR MAY BE CRUSHED STONE OR ANY NON-COMPRESSIBLE MATERIAL. THE FILL SHALL BE COVERED WITH AN IMPERVIOUS MATERIAL BEFORE THE PLACEMENT OF CONCRETE.

CITY OF HIGH POINT
NORTH CAROLINA
ENGINEERING SERVICES DEPARTMENT

APPROVED *BSP* JULY 3, 2007
DIRECTOR

ISSUED 7-3-07
REVISIONS
9-15-10

STANDARD DRAWING FOR

SANITARY MANHOLE ABOVE GROUND

FOR USE IN CONJUNCTION WITH PIERS

MH_INAIR.DWG

315.00

SHEET 1 OF 1