



- NOTES:
1. ENSURE THAT DRAINAGE AREAS DO NOT EXCEED 1 ACRE PER INLET.
 2. KEEP THE HEIGHT OF THE BARRIER AT LEAST 12 INCHES AND NO GREATER THAN 24 INCHES.
 3. IF NEEDED, PLACE 2 x 4 WOOD STUDS THROUGH BLOCK OPENINGS FOR LATERAL SUPPORT.
 4. THIS PRACTICE MUST NOT BE USED NEAR THE EDGE OF FILL MATERIAL AND MUST NOT DIVERT WATER OVER CUT OR FILL SLOPES.

CITY OF HIGH POINT
 NORTH CAROLINA
 ENGINEERING SERVICES DEPARTMENT
 APPROVED... FEBRUARY 17, 2009
 BSK
 DIRECTOR

ISSUED 2-17-09
REVISIONS

STANDARD DRAWING FOR
 BLOCK AND GRAVEL INLET PROTECTION
 FOR STORM DRAIN INLETS