



- NOTES:
1. ENSURE THAT DRAINAGE AREAS DO NOT EXCEED 1 ACRE PER INLET.
 2. KEEP THE MINIMUM VOLUME OF EXCAVATED AREA AROUND THE DROP INLET AT APPROXIMATELY 35 CY/AC DISTURBED.

STANDARD DRAWING FOR
EXCAVATED DROP INLET PROTECTION
 FOR EROSION CONTROL

CITY OF HIGH POINT
 NORTH CAROLINA
 ENGINEERING SERVICES DEPARTMENT
 APPROVED... FEBRUARY 17, 2009
BSP
 DIRECTOR

ISSUED 2-17-09
 REVISIONS

INLPRO EXCAV.DWG

608.03

SHEET 1 OF 1