



RODENT SCREEN @ OUTLET

- NOTES:
- WHEN PROOF ROLLING IS REQUIRED, PLACE PIPE UNDERDRAINS A MINIMUM OF 4' DEEP.
 - CONNECT PIPE OUTLET INTO DRAINAGE STRUCTURE WHEREVER POSSIBLE.
 - CONCRETE PAD:
 - IF PIPE OUTLET IS NOT CONNECTED TO DRAINAGE STRUCTURE, CONNECT PIPE OUTLET TO CONCRETE PAD (SEE SHEET 2).
 - IF SHOWN ON THE PLANS, INSTALL STEEL POST AND ROUND DELINEATOR AT CONCRETE PAD LOCATIONS.

CITY OF HIGH POINT
NORTH CAROLINA
ENGINEERING SERVICES DEPARTMENT

ISSUED 5-3-07

REVISIONS

APPROVED MAY 3, 2007

DIRECTOR

STANDARD DRAWING FOR
PIPE UNDERDRAIN AND BLIND DRAIN

UNDER_DRN_1.DWG

803.00

SHEET 1 OF 2